

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1574:110 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Fairfield, NJ 07004
Contact: *Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Models ADT-PS and ADT-PHS photoelectric smoke detectors. Model ADT-PHS employs an integral 135°F fixed temperature heat sensor. This heat sensor is a supplementary device to the smoke detector and is not approved as a required heat detector. Refer to listee's printed data sheet for additional detailed product description, installation and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with listee's listed fire alarm control units and bases (CSFM Listing No. 7300-1574:106). Model ADT-PS may be suitable for installation directly in the duct with the velocity range from 0-5000 feet/min.

NOTE: Model ADT-PHS is not intended for use in lieu of a required heat detector.

XLF: 7272-1591:126 Formerly 7272-1388:186

*Rev. 07-01-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 1, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager